

Inspection and maintenance of RPZ backflow preventer, type BA acc. EN 806-5

TO BE COMPLETED ONLY AFTER PRIOR STUDY OF THE INSTALLATION AND OPERATING INSTRUCTIONS!



Backflow preventer

Systemtrenner BA
Figure-No.

Year 1		Year 2		Year 3	
Inspection	Maintenance	Inspection	Maintenance	Inspection	Maintenance
Date:	Date:	Date:	Date:	Date:	Date:
Company:	Company:	Company:	Company:	Company:	Company:
Inspector:	Inspector:	Inspector:	Inspector:	Inspector:	Inspector:

Inspection

// Access safety valve

// Visual inspection for leakage at the stop valve and strainer connections

// Check free drain

// Check if water is in the odor trap

Maintenance

// Clean strainer

// Static pressure / dynamic pressure / differential pressure

/ Function test of inlet check valve

/ Function test of discharge valve

/ Function test of outlet check valve

/	/	mbar	/	/	mbar

/
/
/

FORHANDLER I NORGE
Froster AS - Sandviksveien 30, 5036 Bergen - Norge
Tlf: +47 55 36 58 55 • post@froster.no • www.froster.no



Note	Note	Note	Note	Note	Note
------	------	------	------	------	------